

City of Edwardsville			
2017 Lead and Copper Sample Results			
Sample No.	Street	Copper (ug/L)	Lead (ug/L)
IEPA Maximum Contaminant Level		1300	15.0
7083820-02	800 Block of Prickett Avenue	39	<1.0
7074230-01	40 Block of Country Club Drive	870	<1.0
7074230-09	900 Block of St. Louis Street	800	<1.0
7063913-04	600 Block of North Buchanan Street	43	<1.0
7083820-01	800 Block of Prickett Avenue	39	<1.0
7074230-05	1900 Block of Vassar Drive	390	<1.0
7063913-13	400 Block of West 4th Street	610	<1.0
7063913-08	200 Block of Circle Drive	200	<1.0
7063913-14	200 Block of Magnolia Street	97	<1.0
7074230-13	300 Block of South Kansas Street	94	<1.0
7074230-12	300 Block of North Main Street	310	<1.0
7083820-04	400 Block of Hillsboro Avenue	44	<1.0
7083820-03	50 Block of Halleck Avenue	170	<1.0
7063913-11	800 Block of St. Louis Street	38	<1.0
7063913-01	400 Block of Shady Lane	280	<1.0
7074230-04	500 Block of Bollman Avenue	160	<1.0
7063913-02	400 Block of Roanoke Avenue	350	<1.0
7063913-15	300 Block of Clay Street	170	<1.0
7074230-08	1900 Block of McKendree Drive	210	<1.0
7074230-10	20 Block of Washington Place	180	<1.0
7074230-06	1300 Block of Gloucester Drive	180	<1.0
7063913-17	0 Block of Washington Place	110	<1.0
7063913-09	1600 Block of Prairieview Drive	330	<1.0
7074230-03	800 Block of Yale Avenue	240	1.3
7074230-07	1000 Block of East Franklin Avenue	390	1.4
7063913-06	700 Block of Notre Dame Avenue	350	1.4
7063913-07	300 Block of East Lake Drive	550	1.8
7074230-11	800 Block of Grand Avenue	97	2.2
7074230-02	400 Block of West 4th Street	350	3.1
7063913-05	1700 Block of Duke Street	460	3.4

*ug/L - Microgram per Liter