

City of Edwardsville 2020 Lead and Copper Sample Results			
Sample No.	Street	Copper (ug/L)	Lead (ug/L)
IEPA Maximum Contaminant Level		1300	15.0
0095565-03	600 Block of Chapman Street	250	<1.0
0095565-08	400 Block of West 4th Street	390	<1.0
0095565-01	400 Block of West Union	26	<1.0
0084383-07	200 Block of Magnolia Avenue	130	<1.0
0084383-03	400 Block of West 4th Street	780	<1.0
0084383-04	300 Block of Clay Street	140	<1.0
0084383-02	800 Block of Grand Avenue	5.7	<1.0
0095565-07	800 Block of East Lake Drive	570	<1.0
0084383-01	800 Block of St. Louis Street	160	<1.0
0095565-09	1700 Block of Meadow Lane	280	<1.0
0084383-13	200 Block of Circle Drive	170	<1.0
0084383-08	300 Block of South Kansas Street	320	<1.0
0084383-05	300 Block of Clay Street	140	<1.0
0084383-10	1900 Block of McKendree Drive	96	<1.0
0084383-12	700 Block of Notre Dame Avenue	280	<1.0
0095565-13	800 Block of Ann Street	49	<1.0
0084383-15	900 Block of Klein Avenue	670	<1.0
0095565-06	800 Block of East Lake Drive	480	<1.0
0084383-09	0 Block of Biscayne Drive	170	<1.0
0095565-10	0 Block of Washington Place	130	<1.0
0095565-02	600 Block of St. Louis Street	760	<1.0
0084383-14	400 Block of Grandview Drive	160	<1.0
0095565-11	800 Block of Yale Avenue	190	<1.0
0084383-11	300 Block of East Lake Drive	400	<1.0
0095565-12	800 Block of Chancellor Drive	210	<1.0
0095565-05	200 Block of Coventry Place	120	<1.0
0095565-04	400 Block of North Buchanan Street	750	<1.0
0095565-15	200 Block of Crane Street	100	<1.0
0095565-14	500 Block of Buena Vista Drive	290	1.5
0086176-01	300 Block of North Main Street	330	2.9

*ug/L - Microgram per Liter