

Polyfluoroalkyl Substances

TP01 - Sample 1/7/2021		
PFAS Analyte (Acronym)	Guidance Level	Sample Results
Perfluorobutanesulfonic acid (PFBS)	140,000 ng/L (0.14 mg/L)	2.6
Perfluoroheptanoic acid (PFHpA)	-----	ND
Perfluorohexanesulfonic acid (PFHxS)	140 ng/L (0.00014 mg/L)	ND
Perfluorononanoic acid (PFNA)	21 ng/L (0.000021 mg/L)	ND
Perfluorooctanesulfonic acid (PFOS)	14 ng/L (0.000014 mg/L)	ND
Perfluorooctanoic acid (PFOA)	2 ng/L (0.000002 mg/L)	ND
Perfluorodecanoic acid (PFDA)	-----	ND
Perfluorododecanoic acid (PFDoA)	-----	ND
Perfluorohexanoic acid (PFHxA)	560,000 ng/L (0.56 mg/L)	ND
Perfluorotetradecanoic acid (PFTA)	-----	ND
Perfluorotridecanoic acid (PFTrDA)	-----	ND
Perfluoroundecanoic acid (PFUnA)	-----	ND
11 -chlorohexadecafluoro-3-oxanone-1-sulfonic acid (11Cl-PF3ONS)	-----	ND
9 -chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	-----	ND
4, 8-dioxa-3H-perfluorononanoic acid (ADONA)	-----	ND
perfluorooctanesulfonamidoacetic acid	-----	ND
Hexafluoropropylene oxide dimer acid (HFPO-DA)	560 ng/L (0.00056 mg/L)	ND
perfluorooctanesulfonamidoacetic acid	-----	ND

No toxicity criteria available

Minimum Reporting Level (MRL) = 2.0 ng/L

ND = Not Detected

Nanograms per Liter (ng/L) = Part per Trillion (ppt)