

Polyfluoroalkyl Substances

TP01 - Sampled 2/11/2021

PFAS Analyte (Acronym)	Guidance Level	Sample Results
Perfluorobutanesulfonic acid (PFBS)	140,00 ng/L (0.14 mg/L)	3.3
Perfluoroheptanoic acid (PFHpA)	-----	ND
Perfluorohexanesulfonic acid (PFHxS)	140 ng/L (0.00014 mg/L)	ND
Perfluorononanoic acid (PFNA)	21 ng/L (0.000021 mg/L)	ND
Perfluorooctanesulfonic acid (PFOS)	14 ng/L (0.000014 mg/L)	ND
Perfluorooctanoic acid (PFOA)	2 ng/L (0.000002 mg/L)	ND
Perfluorodecanic acid (PFDA)	-----	ND
Perfluorododecanoic acid (PFDoA)	-----	ND
Perfluorohexanoic acid (PFHxA)	560,000 ng/L (0.56 mg/L)	ND
Perfluorotetradecanoic acid (PFTA)	-----	
Perfluorotridecanoic acid (PFTrDA)	-----	ND
Perfluoroundecanoic acid (PFUnA)		
11-chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	-----	ND
9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	-----	ND
4, 8-dioxa-3H-perfluorononanoic acid (ADONA)	-----	ND
N-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	-----	ND
Hexafluoropropylene oxide dimer acid (HFPO-DA)	560 ng/L (0.00056 mg/L)	ND
N-ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	-----	ND

No toxicity criteria available

Minimum Reporting Level (MRL) = 2.0 ng/L

ND = Not Detected

Nanograms per Liter (ng/L) = Part per Trillion (ppt)