

City of Edwardsville 2023 Lead and Copper Sample Results			
Sample No.	Street	Copper (ug/L)	Lead (ug/L)
<b>IEPA Maximum Contaminant Level</b>		<b>1300</b>	<b>15.0</b>
GG02455-10	400 Block of West 4th Street	680	<1.0
GG02455-02	800 Block of Grand Avenue	8.5	<1.0
GG02455-08	800 Block of East Lake Drive	240	<1.0
GG02455-06	200 Block of Circle Drive	21	<1.0
GG02455-09	400 Block of West 4th Street	630	<1.0
GG02455-11	200 Block of Coventry Place	51	<1.0
GG02455-05	700 Block of Notre Dame Avenue	280	<1.0
GG02455-03	800 Block of Yale Avenue	190	<1.0
GG02455-12	300 Block of Clay Street	160	<1.0
GG02455-07	1700 Block of Meadow Lane	490	1.6
GG02455-04	800 Block of Chancellor Drive	250	1.6
GG02455-01	800 Block of Ann Street	75	2.8
GH05844-12	500 Block of Bollman Avenue	190	<1.0
GH03145-01	0 Block of Halleck Ave	300	4.5
GH03145-02	1700 Block of Duke Street	470	<1.0
GH03145-03	300 Block of Clay Street	140	<1.0
GH03145-04	0 Block of Washington Place	310	1.6
GH03145-05	900 Block of St. Louis Street	950	<1.0
GH03145-06	400 Block of Grandview Drive	49	<1.0
GH05844-01	700 Block of Chapman Street	620	10
GH05844-02	800 Block of East Lake Drive	620	<1.0
GH05844-03	600 Block of East Lake Drive	550	6.1
GH05844-04	100 Block of Lautner Lane	560	<1.0
GH05844-05	600 Block of Sherman Avenue	110	<1.0
GH05844-06	1400 Block of Grand Avenue	460	<1.0
GH05844-07	500 Block of Olive Street	960	<1.0
GH05844-08	800 Block of St. Louis Street	970	2.3
GH05844-09	700 Block of East Lake Drive	150	<1.0
GH05844-10	1300 Block of Gerber Road	520	<1.0
GH05844-11	1200 Harrison Street	1000	4.7

\*ug/L - Microgram per Liter